

**Posting Title:** 500 MPa Steel Reinforcement - Structural Implementation

**TCP #:** 000-0065

**Closing Date:** April 7, 2022

<b>Comment</b>	<b>Response</b>
<p>Comment received from outside Technical Consultation Portal (TCP), directly by email. Clarification is required on which drawings require designer to consider the effects of higher reinforcement strengths, and which require simple changing of Grade from 400W to 500W.</p>	<p>Agree. Bullet 2 will be clarified so that all drawings where the designer has design input will require designer to consider effects of higher reinforcement strength. Bullet 3 is modified to clarify that only standard drawings that are already fully designed and require only addition of dimensions or other minor information, will have reinforcement Grade changed from 400W to 500W.</p>