



EQUIPMENT LAYOUT



SCHEMATIC WIRING DIAGRAM



ELECTRICAL EQUIPMENT LIST

- | | |
|---|--|
| ① Main circuit breaker – 100A, 2–pole | ⑮ No. 12 AWG RWU 90 wire |
| ② Branch circuit breakers – 1–pole | ⑯ Field wiring |
| ③ Solid neutral assembly – 100A minimum | ⑰ Ground bus |
| ④ Ground lug for No. 2/0 AWG stranded copper ground wire | ⑱ Bonding (B) conductor required for metered service |
| ⑤ Secondary lightning arrester – 650V, 2–pole | |
| ⑥ Drip shield | |
| ⑦ Branch circuit neutral | |
| ⑧ Primary barrier | |
| ⑨ Secondary barrier | |
| ⑩ Circuit breaker for photoelectric controller and lighting – 15A, 1–pole | |
| ⑪ Circuit breaker for relamping – 15A, 1–pole | |
| ⑫ Terminal block | |
| ⑬ Copper bus bar | |
| ⑭ No. 6 AWG RWU 90 wire | |

NOTE:

A This MTOD shall be read in conjunction with OPSD 2441.010, 2441.020, and 2441.030.

MINISTRY OF TRANSPORTATION ONTARIO DRAWING

Sep 2025

Rev

5

SUPPLY CONTROL CABINET ASSEMBLY TYPE 3

120/240V, 100A, 1–PHASE, 3–WIRE

DRAFT

MTOD 2441.000